

**SCS Global Services** does hereby certify that an independent assessment has been conducted on behalf of:

# Karelia-Upofloor Oy

Souranderintie 2, FI-37101, Nokia, Finland

For the following product(s):

## **Polymeric Flooring:**

LifeLine Tile, Upofloor PVC Free Sheet, Upofloor PVC Free Luxury Tile, Upofloor PVC Free Tile, Upofloor Xpression, Upofloor Zero, Zero Sound

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

## **FloorScore®**

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.0

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m<sup>3</sup> (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-02256

Valid from: December 1, 2017 to November 30, 2018

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Vice President  
SCS Global Services  
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA