



TEST CERTIFICATE



CERTIFIED MATERIAL: Sikafloor®-264 Plus
Smooth floor coating and seal coat based on epoxy resin

CLIENT: Sika Deutschland CH AG & Co KG
Kornwestheimer Straße 103-107
70439 Stuttgart

TESTING LABORATORY: iLF Magdeburg GmbH
Lab Materials Testing

TEST REPORT: 240936

VALIDITY: until January 2030

Test Result:

The decontaminability of the Sikafloor® 264 Plus floor coating, tested according to ISO 8690 Edition 2020 or DIN ISO 8690 Edition 2022, is <EXCELLENT>

Magdeburg, January, 20th 2025

Dr.-Ing. Susanne Bender
CEO

Dr. Ute Holzhausen
Materials testing

