



Sika Deutschland GmbH
Report No. SI 2403-1509

Cleanroom[®] Suitable Materials

Sikafloor-264 Plus
(smooth)

Riboflavin Test: excellent

FLOORING & COATING

Single product Riboflavin Test

Qualification Certificate

We hereby certify that the material stated above, provided by

Sika Deutschland GmbH
Stuttgart, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number SI 2403-1509.

The examination of cleanability of Sikafloor-264 Plus (color: gray) was investigated according to VDMA information sheet. The following test result could be provided:

Material tested	Classification
Sikafloor-264 Plus (smooth)	excellent

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

SI 2403-1509
Report No. first document
--
Report No. current document

Stuttgart, February 19, 2025
Place, date of first document issued
--
Place, current date

on behalf of 
Frank Bürger, Project manager Fraunhofer IPA