

Attestation

AgBB

On the 20th of November 2024, Eurofins Product Testing A/S received a sample of a resin based floor coating with the product name:

Sikafloor-264 Plus

supplied by

Sika Deutschland GmbH

The emissions were tested according to AgBB (AgBB - Committee for Health-related Evaluation of Building Products). Sampling, testing and evaluation were performed according to ISO 16000-3, ISO 16000-6, ISO 16000-9, and ISO 16000-11 testing standards (see the test report no. 392-2024-00541601_D_EN_rev2).

Evaluation of the emission test result according to AgBB:

- The sum of VOC ("TVOC") after 3 days was in compliance with the limit of $\leq 10 \text{ mg/m}^3$.
- The sum of VOC ("TVOC") after 28 days was in compliance with the limit of $\leq 1 \text{ mg/m}^3$.
- The sum of SVOC after 28 days was in compliance with the limit of $\leq 0.1 \text{ mg/m}^3$.
- After 28 days the value R was calculated from the detected VOC with single concentrations above $5 \mu\text{g/m}^3$. This value R was in compliance with the limit of ≤ 1 .
- The sum of VOC without LCI-value after 28 days was in compliance with the limit of $\leq 0.1 \text{ mg/m}^3$.
- The concentration of formaldehyde after 28 days was in compliance with the limit of $\leq 0.1 \text{ mg/m}^3$.
- Carcinogenic substances were not detectable after 3 and after 28 days

The tested product complies with the requirements of AgBB including the LCI-values (June 2021) for use in the indoor environment.

6 January 2025



Rasmus Verdier
Analytical Service Manager