





Number	21-004738-PR44 (NW-K05-02040609-en-01)
Owner	Berner Omnichannel Trading Holding SE Bernerstraße 6 74653 Künzelsau Germany
Product	one component canned foam
Designation	<b>Window foam simple white</b>
Details	Material <b>polyurethane foam</b> Application <b>foam gun</b> Density <b>approx. 19 kg/m<sup>3</sup></b> (manufacturer's information) Colour <b>white</b> Test state <b>foamed with oversize, cut flush / cut to size after curing / conditioning</b>
Results	Decision rule: For the evaluation of conformity, the measurement uncertainty was not taken into account.

	Characteristics	Result of the test
	Air permeability in new condition according to EN 12114	$a < 0.1 \text{ m}^3/[(\text{m h} (\text{daPa})^{2/3})]$ Joint width $w = 20 \text{ mm}$ Joint depth $d = 70 \text{ mm}$
	Sound reduction of joints according to EN ISO 10140-1	$[R_{s,w} (C; C_{tr}) \geq 62 (-1;-5) \text{ dB}]$ Joint width $w = 20 \text{ mm}$ Joint depth $d = 100 \text{ mm}$
	Thermal conductivity according to EN 17333-5	$\lambda_{10} = 0.036 \text{ W}/(\text{m K})$ Insulation board 270 x 270 x 30 mm <sup>3</sup>
	Water vapour resistance factor according to EN ISO 12572 – Climate set A	$\mu_{0/50} = 21$ Insulation cylinder $t = 94 \text{ mm}, d = 70 \text{ mm}$

ift Rosenheim  
16.07.2024



Wolfgang Jehl, Dipl.-Ing. (FH)  
Deputy Head of Testing Department  
Building Component Testing



Martin Heßler, Dipl.-Ing. (FH)  
Project Engineer  
Building Component Testing

### Basis \*)

EN 12114 : 2000  
EN ISO 10140-1 : 2021  
EN 17333-5 : 2020  
EN ISO 12572 : 2016

\*) and the equivalent national versions (e.g. DIN EN)

ift-Nachweis:  
21-004738-PR23  
(NW-K05-02040609-en-02)

ift Product certification QM 360  
contract no. 188 9026567 dated  
02.09.2022

### Representation



### Instructions for use

The results obtained can be used as evidence in accordance with the above basis.

### Validity

There is no time limit.  
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

The data and results given relate solely to the tested/described specimen. This test/evaluation does not allow any statement to be made on further characteristics of the present structure regarding performance and quality.

### Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies..

### Identity-Check



[www.ift-rosenheim.de/ift-geprueft](http://www.ift-rosenheim.de/ift-geprueft)  
ID: 27F-F412F