

Attestation

LEED v4, v4.1 BETA, and v5

On the 11th of June 2026, Eurofins Product Testing A/S received a sample of a non-wooden panel with the product name:

Rigips Duraline DL

supplied by

Saint-Gobain Austria GmbH

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the CDPH 01350 testing standards (See test report no. 392-2026-00310201_H_EN).

Deviations from the referenced test methods were registered. (See section 4.4 in test report no. 392-2026-00310201_H_EN).

The test results of the tested sample indicate that the product qualifies for LEED v4, LEED v4.1 BETA (November 2025), and LEED v5 (February 2026) projects globally by showing compliance with the specifications for VOC emissions and VOC content by complying with:


VOC emissions specifications in LEED EQ credit "Low-Emitting Materials" for LEED projects globally:

- The requirements of LEED v4, LEED v4.1 BETA (November 2025) and LEED v5 (February 2026) by: CDPH-IAQ (California Department of Public Health (CDPH) Standard Method v1.2-2017); and a TVOC below 0.5 mg/m³ in both office and classroom.

12 August 2026



Isabella B. Larsen
Analytical Service Manager



Claus Bonde
Analytical Service Manager

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.